

Wir, die

### F. W. Oventrop GmbH & Co. KG

Paul-Oventrop-Str.1  
D-59939 Olsberg

erklären in alleiniger Verantwortung, dass die folgenden Produkte mit  
folgenden Normen oder normativen Dokumenten übereinstimmen:

**DIN 3842**

Produkt

### „Combi 3“ Verschraubungen


Art. – Nr.	DN [mm]	PN [bar]	Temperatur- Bereich [°C]	CE- Zeichen
109 03 61	10	10	Bis 120°C	Nein
109 03 62	15			
109 03 63	20			
109 04 61	10			
109 04 62	15			
109 04 63	20			


Überwachung QS-System:

Überwachung während der Fertigung:

DQS 000211 QM  
OVENTROP

Olsberg, den 22.08.2006

i.V.   
Dr. Ing. Foitzik  
Technischer Leiter

i.V.   
Dipl.-Ing. Wundling  
Projekt Leiter

We, **F. W. Oventrop GmbH & Co. KG**

Paul-Oventrop-Str.1  
D-59939 Olsberg

Hereby declare at sole responsibility that the following products to which this declaration refers, correspond to the standards and technical specifications

**DIN 3842**

Product


**Radiator lockschild valves "Combi 3"**


Item no.	DN [mm]	PN [bar]	Temperature range [°C]	CE- Marking
109 03 61	10	10	Up to 120°C	No
109 03 62	15			
109 03 63	20			
109 04 61	10			
109 04 62	15			
109 04 63	20			

Monitoring quality management system:  
Surveillance during production:

DQS 000211 QM  
OVENTROP

Olsberg, 22.08.2006

i.V.   
Dr. Ing. Foitzik  
Technical director

i.V.   
Dipl.-Ing. Wundling  
Project manager