

Wir, die

Oventrop GmbH & Co. KG

Paul-Oventrop-Str 1
D-59939 Olsberg

erklären in alleiniger Verantwortung, dass die folgenden Produkte mit
den Anforderungen konform sind, die in der

Richtlinie 97/23/EG

festgelegt sind

Produkt

Schmutzfänger, aus Rotguss

Art. – Nr	DN [mm]	PN [bar]	Temperatur- Bereich [°C]	Fluidgruppe	CE-Zeichen	Modul
112 00 02	8	25	-10 / +150	Artikel 3 Absatz 1.3 a Fluide d. Gruppe 2	Nein *)	
112 00 03	10					
112 00 04	15					
112 00 06	20					
112 00 08	25					
112 00 10	32					
112 00 12	40					
112 00 16	50				Ja	A
112 00 20	65					
112 00 24	80				Nein *)	
112 10 02	8					
112 10 03	10					
112 10 04	15					
112 10 06	20					
112 10 08	25					
112 10 10	32					
112 10 12	40					
112 10 16	50				Ja	A
112 10 20	65					
112 10 24	80					

*) Diese Schmutzfänger fallen unter Artikel 1 Absatz 3 der Druckgeräterichtlinie 97/23/EG und dürfen keine CE-Kennzeichnung erhalten.

Angewandte Normen und technische Spezifikation:

Überwachung QM-System:


DQS 000211 QM

Überwachung während der Fertigung:

OVENTROP / DVGW

Olsberg, den 19.07.2012

i.V.



Dr. Ing. Foitzik
Technischer Leiter

i.V.



Dipl.-Ing. Löffler
Projekt Leiter

We, **Oventrop GmbH & Co. KG**

Paul-Oventrop-Str 1
D-59939 Olsberg

hereby declare at sole responsibility that the following products
to which this certificate refers, correspond to
EU-Directive 97/23/EC

Product

"Y" type strainers, made of bronze

Item no.	DN [mm]	PN [bar]	Temperature range [°C]	Group of fluids	CE-marking	Module
112 00 02	8	25	-10 / +150	Article 3 paragraph 1.3 a fluids of group 2	No *)	
112 00 03	10					
112 00 04	15					
112 00 06	20					
112 00 08	25					
112 00 10	32					
112 00 12	40					
112 00 16	50				Yes	A
112 00 20	65					
112 00 24	80				No *)	
112 10 02	8					
112 10 03	10					
112 10 04	15					
112 10 06	20					
112 10 08	25					
112 10 10	32					
112 10 12	40				Yes	A
112 10 16	50					
112 10 20	65					
112 10 24	80					

*) Article 1 paragraph 3 of EU-Directive 97/23/EC applies to these "Y" type strainers and they are not allowed to carry a CE-marking.

Used standards and technical specifications:

Monitoring quality management system:
Surveillance during production:

DQS 000211 QM
OVENTROP / DVGW

Olsberg, 19.07.2012

i.V.


Dr Ing. Foitzik
Technical director

i.V.


Dipl.-Ing. Löffler
Project manager