

Wir, die

F. W. Oventrop GmbH & Co. KG

Paul-Oventrop-Str. 1
D-59939 Olsberg

erklären in alleiniger Verantwortung, dass die folgenden Produkte mit folgenden Normen oder normativen Dokumenten übereinstimmen:

Rohrleitungsanschluss nach DIN V 3838

Produkt

„Multiflex F“ Anschlussarmaturen

Art. – Nr.	Max. Betriebs- druck p _s	Betriebstemperatur- Bereich t _s	CE- Zeichen
101 58 80	10 bar (PN10)	2°C - 120°C	Nein
101 58 83			
101 58 84			
101 57 81			
101 59 93			
101 59 94			
101 59 33			
101 59 34			

Überwachung QS-System:

DQS 000211 QM

Überwachung während der Fertigung:


OVENTROP

Olsberg, den 05.05.2008

i.V.


Dr. Ing. Foitzik
Technischer Leiter

i.V.


Dipl.-Ing. Wundling
Projektleiter

We, **F. W. Oventrop GmbH & Co. KG**

Paul-Oventrop-Str. 1
D-59939 Olsberg

Hereby declare at sole responsibility that the following products to which this declaration refers, correspond to the standards and technical specifications

pipework connection according to DIN V 3838

Product

Connection fittings "Multiflex F"


Item no.	Max. working pressure ps	Working temperature range ts	CE- Marking
101 58 80	10 bar (PN10)	2°C - 120°C	No
101 58 83			
101 58 84			
101 57 81			
101 59 93			
101 59 94			
101 59 33			
101 59 34			

Monitoring quality management system:
Surveillance during production:

DQS 000211 QM
OVENTROP

Olsberg, 05.05.2008

i.V. _____
Dr. Ing. Foitzik
Technical director

i.V.  _____
Dipl.-Ing. Wundling
Project manager